

Cleaning Pros Plus

(209) 318-2737 · cleaningprosplus.com

CERTIFICATE OF SERVICE

NFPA 96 (2021 ed.), as referenced in the 2025 California Fire Code

CPP-K-2026-00148

This certifies that the commercial kitchen exhaust system identified below was professionally cleaned and inspected to the standard cited on the service date shown.

Service Record

Service Company	Cleaning Pros Plus
Client Served	Harbor House Restaurant
Address	1200 Harbor House Way, Oakland, CA 94607
Services Performed	Kitchen Exhaust Cleaning
Service Schedule	Quarterly
Service Date	August 18, 2026
See Report	CPP-K-2026-00148
Next Service Due	November 18, 2026
Lead Technician	Samuel Haggerty, PECT #200476

Standards & Codes of Compliance

NFPA 96 (2021 ed.), as referenced in the 2025 California Fire Code

ANSI/IKECA C10 — Standard for the cleaning of commercial kitchen exhaust systems.

California Fire Code — Ch. 6, §609 (Commercial Kitchen Hoods), and all applicable state and local fire codes.

Protective Safeguards Endorsement (ISO CP 04 11) — P-5 automatic commercial cooking exhaust and extinguishing system (hood, grease-removal device, duct, wet-chemical); P-9 the protective system described in the Schedule. Impairment of a named safeguard must be reported to the insurer, or coverage for a fire loss may be reduced or denied.



Cleaning Pros Plus
IKECA Member #76716495
Exp. 3/1/2027

Arthur L. Haggerty

Arthur L. Haggerty, Jr., M.S.
Founder & CEO · CECS #200452

Ongoing compliance remains the responsibility of the property owner or operator per NFPA 96 §4.1.5. Determination of code compliance is the responsibility of the authority having jurisdiction.